

CARMEL AREA WASTEWATER DISTRICT

Semi-Annual Biosolids Monitoring Report

Period: April 2013-September 2013
 Sample Date: 4-Sep-13

Name POLLUTANTS	Concentration (mg/kg) Dry Weight unless indicated	EPA 503 pollution limits for land application	
		Pollutant Concentrations (40 CFR 503.13) (monthly avg.)	Ceiling Concentrations (40 CFR 503.13) (daily maximum)
Arsenic	3.1	41 mg/Kg	75 mg/Kg
Cadmium	1.6	39 mg/Kg	85 mg/Kg
Chromium	17.0	1200 mg/Kg	3000 mg/Kg
Copper	780.0	1500 mg/Kg	4300 mg/kg
Lead	12.0	300 mg/Kg	840 mg/kg
Mercury	0.6	17 mg/Kg	57 mg/Kg
Molybdenum	11.0	18 mg/Kg	75 mg/Kg
Nickel	19.0	420 Mg/Kg	420 mg/Kg
Selenium	5.4	100 mg/Kg	100 mg/Kg
Zinc	1500.0	2800 mg/Kg	7500 mg/Kg
Hex Chromium	ND		
Boron	100.0		
Silver	5.3		
Antimony	ND		
Barium	250.0		
Beryllium	ND		
Cobalt	ND		
Thallium	ND		
Vanadium	4.8		
Cyanide	2		
Total Phosphorus	15,000		
Total Kjeldahl Nitrogen	64,000		
Ammonia Nitrogen	6400		
Nitrate Nitrogen	ND		
Total Solids	16.0%		
pH units	7.98		

Pathogen Reduction (40 CFR 503.32)

Class B - (PSRP) Anaerobic Digestion at 95 F for minimum of 15 days


Vector Attraction Reduction (40 CFR 503.33)

Option 1 - VS reduced by a minimum of 38%

Certification

I certify, under penalty of law, that the Class B pathogen requirements in 503.32 and the vector attraction reduction requirement in 503.33 using option (1) have been met. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the pathogen and vector attraction reduction requirements have been met. I am aware that there are significant penalties for false certification including fine and imprisonment".

Name & Title: James Pinkevich - Plant Manager

Signature: 

Telephone Number: (831) 624-1249

Date: _____

Title 22 Certification for Non-Hazardous Material

I certify under penalty of law, that the requirements in 22 CCR, Division 4.5, Chapter 11, Article 3 (Title 22) have been met. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the requirements have been met. I am aware that there are significant penalties for false certification, including the possibility of fine and imprisonment.

Name (please Print)

Official Title

James Pinkevich

Plant Manager

Signature

Date Signed



Oct. 30, 2013

Facility Name

Address

Carmel Area Wastewater District

P.O. Box 221428 Carmel, CA. 93922

Date: January 29, 2014
Division of Water Quality
C/O DMR Processing Center
P.O. Box 100
Sacramento, CA 95812-1000



Facility Name: Carmel Area Wastewater District

Address (mailing): P.O. Box 221428, Carmel, CA 93922

Address (shipping): Highway One & Carmel River, Carmel, CA 93923

Contact Person: James Pinkevich

Job Title: Superintendent

Phone Number: 831-624-1249

WDR/NPDES Order Number: #R3-2008-0007 (NPDES Permit – CA0047996)

WDID Number: 3 270101001

Type of Report (circle one): Monthly Quarterly Semi-Annual Annual

Month(s) (circle applicable Months*):

Jan	Feb	March	Apr	May	Jun
Jul	Aug	Sept	Oct	Nov	Dec

*Annual Reports (circle the first month of the reporting period)

Year: 2013

Violation(s): No (there are no violations to report) Yes
If Yes is marked (complete a-g):

a) Parameter(s) in Violation: n/a

b) Section(s) of WDR/NPDES Violated: n/a

c) Reported Value(s): n/a

d) WDR/NPDES Limit Condition: n/a

e) Dates of Violation(s): n/a

f) Explanation of Cause(s): n/a

g) Corrective Action(s): n/a
(attach additional information as needed)

In accordance with the Standard Provisions and Reporting Requirements, I certify under penalty of law that this document and all attachments were prepared under my direction or supervision following a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my knowledge of the person(s) who manage the system or those directly responsible for data gathering, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment.

If you have any questions or require additional information, please contact me at the number provided above.

Sincerely,



James Pinkevich
Superintendent

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: CARMEL AREA WWD & PEBBLE BEACH
ADDRESS: 26900 STATE ROUTE ONE
CARMEL, CA 93922

FACILITY: CARMEL AREA WWTP
LOCATION: 26900 STATE ROUTE ONE
CARMEL, CA 93922

ATTN: James Pinkevich

CA0047996
PERMIT NUMBER

001-S
DISCHARGE NUMBER

DMR Mailing ZIP CODE: 93922
MAJOR

(SUBR 03)
DISCHARGE 001/SEMIANNUALLY
External Outfall

MONITORING PERIOD
MM/DD/YYYY TO MM/DD/YYYY
07/01/2013 TO 12/31/2013

No Discharge

PARAMETER	QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
	VALUE	UNITS	VALUE	VALUE	UNITS	VALUE			
Radioactivity	*****	*****	*****	*****	*****	*****			
00189 1 0 Effluent Gross	*****	*****	*****	*****	*****	*****			
Cyanide, total (as CN)	0.7	lb/d	0.7	86	ug/L	86		Twice Per Year	COMP24
00720 1 0 Effluent Gross	3.1	lb/d	12	490	ug/L	1220		Twice Per Year	COMP24
Arsenic, total recoverable	0.01	lb/d	0.01	0.6	ug/L	0.6		Twice Per Year	COMP24
00978 1 0 Effluent Gross	15	lb/d	89	3540	ug/L	9400		Twice Per Year	COMP24
Selenium, total recoverable	0.01	lb/d	0.01	0.6	ug/L	0.6		Twice Per Year	COMP24
00981 1 0 Effluent Gross	46	lb/d	180	7320	ug/L	18300		Twice Per Year	COMP24
Thallium, total recoverable	0.01 (CS)	lb/d	0.01 (CS)	0.6 (CS)	ug/L	0.6 (CS)		Twice Per Year	COMP24
00982 1 0 Effluent Gross	6.1	lb/d	30DA AVG	240	ug/L	240		Twice Per Year	COMP24
Beryllium, total recoverable (as Be)	0.01 (CS)	lb/d	0.01 (CS)	0.6 (CS)	ug/L	0.6 (CS)		Twice Per Year	COMP24
00998 1 0 Effluent Gross	1	lb/d	30DA AVG	4.03	ug/L	4.03		Twice Per Year	COMP24
Chromium, hexavalent (as Cr)	0.01 (CS)	lb/d	0.01 (CS)	0.6 (CS)	ug/L	0.6 (CS)		Twice Per Year	COMP24
01032 1 0 Effluent Gross	6.1	lb/d	24	980	ug/L	2440		Twice Per Year	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
DAVIDA BULLERA
GENERAL MANAGER

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and analyze the information submitted, that the information submitted is true and complete, and that I am aware that there are significant civil penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT


TELEPHONE DATE
831 624-1249 01/29/2014
AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NOTE THAT THE UG/L LIMITS FOR DIMETHYL PHTHALATE WERE CONVERTED TO MG/L DUE TO 8 DIGIT LIMIT IN PCS. NOTE THAT THE UG/L AND LBS/DAY LIMITS FOR TCDD EQUIVALENTS WERE CONVERTED TO PG/L AND UG/DAY.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: CARMEL AREA WWD & PEBBLE BEACH
ADDRESS: 26900 STATE ROUTE ONE
CARMEL, CA 93922

FACILITY: CARMEL AREA WWTP
LOCATION: 26900 STATE ROUTE ONE
CARMEL, CA 93922

ATTN: James Pinkevich

CA0047996
PERMIT NUMBER

001-S
DISCHARGE NUMBER


DMR Mailing ZIP CODE: 93922
MAJOR (SUBR 03)

DISCHARGE 001/SEMIANNUALLY
External Outfall

No Discharge

MONITORING PERIOD
MM/DD/YYYY TO MM/DD/YYYY
07/01/2013 TO 12/31/2013

PARAMETER	QUANTITY OR LOADING		QUALITY OR CONCENTRATION		NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
	VALUE	UNITS	VALUE	UNITS			
Chromium, trivalent (as Cr)	SAMPLE MEASUREMENT	*****	*****	*****			
	PERMIT REQUIREMENT	580000 30DA AVG	lb/d	23180000 30DA AVG	ug/L	Twice Per Year	COMP24
Nickel, total recoverable	SAMPLE MEASUREMENT	6.84	lb/d	5.3			
	PERMIT REQUIREMENT	15 6 MO MED	lb/d	2440 DAILY MX	ug/L	Twice Per Year	COMP24
Silver total recoverable	SAMPLE MEASUREMENT	1.7	lb/d	70 6 MO MED			
	PERMIT REQUIREMENT	6 MO MED	lb/d	330 DAILY MX	ug/L	Twice Per Year	COMP24
Cadmium, total recoverable	SAMPLE MEASUREMENT	3.1	lb/d	120 6 MO MED			
	PERMIT REQUIREMENT	6 MO MED	lb/d	490 DAILY MX	ug/L	Twice Per Year	COMP24
01114 10 Effluent Gross	SAMPLE MEASUREMENT	6.1	lb/d	240 6 MO MED			
	PERMIT REQUIREMENT	6 MO MED	lb/d	980 DAILY MX	ug/L	Twice Per Year	COMP24
Antimony, total recoverable	SAMPLE MEASUREMENT	3700	lb/d	150000 30DA AVG			
	PERMIT REQUIREMENT	30DA AVG	lb/d	26840 30DA AVG	ug/L	Twice Per Year	COMP24
2-Methyl-4,6-dinitrophenol	SAMPLE MEASUREMENT	670	lb/d	26840 30DA AVG			
	PERMIT REQUIREMENT	30DA AVG	lb/d	26840 30DA AVG	ug/L	Twice Per Year	COMP24

NAME/TITLE BARBARA BURKINA GENERAL MANAGER	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT 	TELEPHONE (831) 624-1249	DATE 01/29/2014
TYPED OR PRINTED		AREA Code 831	NUMBER 624-1249
COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)		MM/DD/YYYY MM/DD/YYYY	

NOTE THAT THE UG/L LIMITS FOR DIMETHYL PHTHALATE WERE CONVERTED TO MGL DUE TO 8 DIGIT LIMIT IN PCS. NOTE THAT THE UG/L AND LBS/DAY LIMITS FOR TCDD EQUIVALENTS WERE CONVERTED TO PG/L AND UG/DAY.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: CARMEL AREA WWD & PEBBLE BEACH
ADDRESS: 26900 STATE ROUTE ONE
CARMEL, CA 93922

CA0047996
PERMIT NUMBER

001-S
DISCHARGE NUMBER

DMR Mailing ZIP CODE: 93922

MAJOR

FACILITY: CARMEL AREA WWTP

LOCATION: 26900 STATE ROUTE ONE
CARMEL, CA 93922

(SUBR 03)
DISCHARGE 001/SEMIANNUALLY
External Outfall

No Discharge


ATTN: James Pinkevich

MONITORING PERIOD

MM/DD/YYYY TO MM/DD/YYYY

01/01/2013 TO 06/30/2013

PARAMETER	QUANTITY OR LOADING		QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
	VALUE	UNITS	VALUE	UNITS	VALUE	UNITS			
Tributyltin 03824 1 0 Effluent Gross	SAMPLE MEASUREMENT	0.043	30DA AVG	None (CS)	*****	None (CS)	30DA AVG	*****	
	PERMIT REQUIREMENT		lb/d				ug/L		Twice Per Year COMP24
Polynuclear Aromatic Hydrocarbons (Method 610) 22456 1 0 Effluent Gross	SAMPLE MEASUREMENT	0.027	30DA AVG	None (CS)	*****	None (CS)	30DA AVG	*****	
	PERMIT REQUIREMENT		lb/d				ug/L		Twice Per Year COMP24
Dichlorobromomethane 32101 1 0 Effluent Gross	SAMPLE MEASUREMENT	19	30DA AVG	None (CS)	*****	None (CS)	30DA AVG	*****	
	PERMIT REQUIREMENT		lb/d				ug/L		Twice Per Year COMP24
Carbon tetrachloride 32102 1 0 Effluent Gross	SAMPLE MEASUREMENT	2.7	30DA AVG	None (CS)	*****	None (CS)	30DA AVG	*****	
	PERMIT REQUIREMENT		lb/d				ug/L		Twice Per Year COMP24
1,2-Dichloroethane 32103 1 0 Effluent Gross	SAMPLE MEASUREMENT	85	30DA AVG	None (CS)	*****	None (CS)	30DA AVG	*****	
	PERMIT REQUIREMENT		lb/d				ug/L		Twice Per Year COMP24
Dibromochloromethane 32105 1 0 Effluent Gross	SAMPLE MEASUREMENT	26	30DA AVG	None (CS)	*****	None (CS)	30DA AVG	*****	
	PERMIT REQUIREMENT		lb/d				ug/L		Twice Per Year COMP24
Chloroform 32106 1 0 Effluent Gross	SAMPLE MEASUREMENT	400	30DA AVG	3.7	*****	15900	30DA AVG	*****	
	PERMIT REQUIREMENT		lb/d				ug/L		Twice Per Year COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER DARBARA BUKENA GENERAL MANAGER	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT 	TELEPHONE (831) 624-1249	DATE 01/29/2014
TYPED OR PRINTED		AREA CODE	NUMBER
			MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NOTE THAT THE UGL LIMITS FOR DIMETHYL PHTHALATE WERE CONVERTED TO MG/L DUE TO 8 DIGIT LIMIT IN PCS. NOTE THAT THE UGL AND LBS/DAY LIMITS FOR TCDD EQUIVALENTS WERE CONVERTED TO PG/L AND UG/DAY.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: CARMEL AREA WWD & PEBBLE BEACH
ADDRESS: 26900 STATE ROUTE ONE
CARMEL, CA 93922

CA0047996
PERMIT NUMBER

001-S
DISCHARGE NUMBER

DMR Mailing ZIP CODE: 93922
MAJOR (SUBR 03)

FACILITY: CARMEL AREA WWTP

LOCATION: 26900 STATE ROUTE ONE
CARMEL, CA 93922


MONITORING PERIOD
MM/DD/YYYY TO MM/DD/YYYY
07/01/2013 TO 12/31/2013

DISCHARGE 001/SEMIANNUALLY
External Outfall

ATTN: James Pinkevich

No Discharge

PARAMETER	QUANTITY OR LOADING		QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
	VALUE	UNITS	VALUE	UNITS	VALUE	UNITS			
Toluene									
34010 10 Effluent Gross	MEASUREMENT	260000	30DA AVG	NOI (US)	10370000	30DA AVG	ug/L	Twice Per Year	COMP24
	PERMIT REQUIREMENT								
Benzene									
34030 10 Effluent Gross	MEASUREMENT	18	30DA AVG	NOI (US)	720	30DA AVG	ug/L	Twice Per Year	COMP24
	PERMIT REQUIREMENT								
Acrolein									
34210 10 Effluent Gross	MEASUREMENT	670	30DA AVG	NOI (US)	26840	30DA AVG	ug/L	Twice Per Year	COMP24
	PERMIT REQUIREMENT								
Acrylonitrile									
34215 10 Effluent Gross	MEASUREMENT	31	30DA AVG	NOI (US)	12.2	30DA AVG	ug/L	Twice Per Year	COMP24
	PERMIT REQUIREMENT								
Bis(2-chloroethyl) ether									
34273 10 Effluent Gross	MEASUREMENT	14	30DA AVG	NOI (US)	5.49	30DA AVG	ug/L	Twice Per Year	COMP24
	PERMIT REQUIREMENT								
Bis(2-chloroethoxy)methane									
34278 10 Effluent Gross	MEASUREMENT	13	30DA AVG	NOI (US)	540	30DA AVG	ug/L	Twice Per Year	COMP24
	PERMIT REQUIREMENT								
Bis(2-chloroisopropyl) ether									
34283 10 Effluent Gross	MEASUREMENT	3700	30DA AVG	NOI (US)	15000	30DA AVG	ug/L	Twice Per Year	COMP24
	PERMIT REQUIREMENT								

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER BARBARA BUIKEMA GENERAL MANAGER	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT 	TELEPHONE (831) 624-1249	DATE 01/29/2014
TYPED OR PRINTED		AREA Code	NUMBER
COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)		MMDDYYYY MMDDYYYY	

NOTE THAT THE UG/L LIMITS FOR DIMETHYL PHTHALATE WERE CONVERTED TO MG/L DUE TO 8 DIGIT LIMIT IN PCS. NOTE THAT THE UG/L AND LBS/DAY LIMITS FOR TCDD EQUIVALENTS WERE CONVERTED TO PG/L AND UG/DAY.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: CARMEL AREA WWD & PEBBLE BEACH
ADDRESS: 26900 STATE ROUTE ONE
CARMEL, CA 93922

CA0047996
PERMIT NUMBER

001-S
DISCHARGE NUMBER

DMR Mailing ZIP CODE: 93922
MAJOR (SUBR 03)
DISCHARGE 001/SEMIANNUALLY
External Outfall

FACILITY: CARMEL AREA WWTP
LOCATION: 26900 STATE ROUTE ONE
CARMEL, CA 93922

MONITORING PERIOD
MM/DD/YYYY TO MM/DD/YYYY
07/01/2013 TO 12/31/2013

ATTN: James Pinkevich

No Discharge

PARAMETER	SAMPLE MEASUREMENT PERMIT REQUIREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	UNITS	VALUE	VALUE	UNITS	VALUE			
Chlorobenzene 34301 1 0 Effluent Gross	MEASUREMENT	None (B)	*****	*****	None (B)	*****	*****			
	PERMIT REQUIREMENT	1700 30DA AVG	lb/d	*****	69540 30DA AVG	ug/L	*****	Twice Per Year	COMP24	
Diethyl phthalate 34336 1 0 Effluent Gross	MEASUREMENT	None (B)	*****	*****	None (B)	*****	*****			
	PERMIT REQUIREMENT	100000 30DA AVG	lb/d	*****	4030000 30DA AVG	ug/L	*****	Twice Per Year	COMP24	
Dimethyl phthalate 34341 1 0 Effluent Gross	MEASUREMENT	None (B)	*****	*****	None (B)	*****	*****			
	PERMIT REQUIREMENT	2500000 30DA AVG	lb/d	*****	100040 30DA AVG	mg/L	*****	Twice Per Year	COMP24	
1,2-Diphenylhydrazine 34346 1 0 Effluent Gross	MEASUREMENT	None (B)	*****	*****	None (B)	*****	*****			
	PERMIT REQUIREMENT	.49 30DA AVG	lb/d	*****	19.52 30DA AVG	ug/L	*****	Twice Per Year	COMP24	
Ethylbenzene 34371 1 0 Effluent Gross	MEASUREMENT	None (B)	*****	*****	None (B)	*****	*****			
	PERMIT REQUIREMENT	13000 30DA AVG	lb/d	*****	500000 30DA AVG	ug/L	*****	Twice Per Year	COMP24	
Fluoranthene 34376 1 0 Effluent Gross	MEASUREMENT	None (B)	*****	*****	None (B)	*****	*****			
	PERMIT REQUIREMENT	46 30DA AVG	lb/d	*****	1830 30DA AVG	ug/L	*****	Twice Per Year	COMP24	
Hexachlorocyclopentadiene 34386 1 0 Effluent Gross	MEASUREMENT	None (B)	*****	*****	None (B)	*****	*****			
	PERMIT REQUIREMENT	180 30DA AVG	lb/d	*****	7080 30DA AVG	ug/L	*****	Twice Per Year	COMP24	

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
BARBARA BUKEMA
GENERAL MANAGER
TYPED OR PRINTED

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT
[Signature]

TELEPHONE DATE
(851)624-1249 05/19/2014
AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NOTE THAT THE UG/L LIMITS FOR DIMETHYL PHTHALATE WERE CONVERTED TO MG/L DUE TO 8 DIGIT LIMIT IN PCS. NOTE THAT THE UG/L AND LBS/DAY LIMITS FOR TCDD EQUIVALENTS WERE CONVERTED TO PGB/L AND UG/DAY.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: CARMEL AREA WWD & PEBBLE BEACH
ADDRESS: 26900 STATE ROUTE ONE
CARMEL, CA 93922

FACILITY: CARMEL AREA WWTP
LOCATION: 26900 STATE ROUTE ONE
CARMEL, CA 93922

ATTN: James Pinkevich

CA0047996
PERMIT NUMBER

001-S
DISCHARGE NUMBER

DMR Mailing ZIP CODE: 93922

MAJOR

(SUBR 03)

DISCHARGE 001/SEMIANNUALLY
External Outfall

No Discharge

MONITORING PERIOD
MM/DD/YYYY TO MM/DD/YYYY
07/01/2013 TO 12/31/2013

PARAMETER	SAMPLE MEASUREMENT REQUIREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	UNITS	VALUE	UNITS	VALUE	UNITS			
Hexachlorobutadiene	34391 1 0 Effluent Gross	43	30DA AVG	NOPI (B)	1710	30DA AVG	ug/L		Twice Per Year	COMP24
	Hexachloroethane	76	30DA AVG	NOPI (B)	310	30DA AVG	ug/L		Twice Per Year	COMP24
Isophorone	34408 1 0 Effluent Gross	2228	30DA AVG	NOPI (B)	89060	30DA AVG	ug/L		Twice Per Year	COMP24
	Methylene chloride	1400	30DA AVG	NOPI (B)	54900	30DA AVG	ug/L		Twice Per Year	COMP24
N-Nitrosodi-N-propylamine	34423 1 0 Effluent Gross	1.2	30DA AVG	NOPI (B)	46	30DA AVG	ug/L		Twice Per Year	COMP24
	34428 1 0 Effluent Gross	76	30DA AVG	NOPI (B)	310	30DA AVG	ug/L		Twice Per Year	COMP24
N-Nitrosodimethylamine (NDMA)	34433 1 0 Effluent Gross	22	30DA AVG	NOPI (B)	890	30DA AVG	ug/L		Twice Per Year	COMP24
	34438 1 0 Effluent Gross									

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER BARBARA BULKEA GENERAL MANAGER	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT 	TELEPHONE (851) 624-1249	DATE 01/29/2014
TYPED OR PRINTED		AREA Code	NUMBER
			MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NOTE THAT THE UG/L LIMITS FOR DIMETHYL PHTHALATE WERE CONVERTED TO MG/L DUE TO 8 DIGIT LIMIT IN PCS. NOTE THAT THE UG/L AND LBS/DAY LIMITS FOR TCDD EQUIVALENTS WERE CONVERTED TO PG/L AND UG/DAY.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: CARMEL AREA WWD & PEBBLE BEACH
ADDRESS: 26900 STATE ROUTE ONE
CARMEL, CA 93922

FACILITY: CARMEL AREA WWTP
LOCATION: 26900 STATE ROUTE ONE
CARMEL, CA 93922

ATTN: James Pinkevich

CA0047996
PERMIT NUMBER

001-S
DISCHARGE NUMBER

DMR Mailing ZIP CODE: 93922

MAJOR

(SUBR 03)

DISCHARGE 001/SEMIANNUALLY

External Outfall


No Discharge

MONITORING PERIOD
MM/DD/YYYY TO MM/DD/YYYY
07/01/2013 TO 12/31/2013

PARAMETER	QUANTITY OR LOADING		QUALITY OR CONCENTRATION		NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
	VALUE	UNITS	VALUE	UNITS			
Nitrobenzene	SAMPLE MEASUREMENT	NOI (B)	*****	*****			
	PERMIT REQUIREMENT	15 30DA AVG	lb/d	500 30DA AVG	ug/L	Twice Per Year	COMP24
Tetrachloroethylene	SAMPLE MEASUREMENT	NOI (B)	*****	*****			
	PERMIT REQUIREMENT	6.1 30DA AVG	lb/d	244 30DA AVG	ug/L	Twice Per Year	COMP24
1,1-Dichloroethylene	SAMPLE MEASUREMENT	NOI (B)	*****	*****			
	PERMIT REQUIREMENT	2.7 30DA AVG	lb/d	110 30DA AVG	ug/L	Twice Per Year	COMP24
34501 1 0 Effluent Gross	SAMPLE MEASUREMENT	NOI (B)	*****	*****			
	PERMIT REQUIREMENT	160000 30DA AVG	lb/d	65880000 30DA AVG	ug/L	Twice Per Year	COMP24
1,1,2-Trichloroethane	SAMPLE MEASUREMENT	NOI (B)	*****	*****			
	PERMIT REQUIREMENT	29 30DA AVG	lb/d	1147 30DA AVG	ug/L	Twice Per Year	COMP24
34516 1 0 Effluent Gross	SAMPLE MEASUREMENT	NOI (B)	*****	*****			
	PERMIT REQUIREMENT	7 30DA AVG	lb/d	280 30DA AVG	ug/L	Twice Per Year	COMP24
1,4-Dichlorobenzene	SAMPLE MEASUREMENT	NOI (B)	*****	*****			
	PERMIT REQUIREMENT	55 30DA AVG	lb/d	2200 30DA AVG	ug/L	Twice Per Year	COMP24

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
BARBARA BULKEMA
GENERAL MANAGER
TYPED OR PRINTED

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT


TELEPHONE
(831) 624-1249
DATE
01/16/2013
AREA Code NUMBER
MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NOTE THAT THE UG/L LIMITS FOR DIMETHYL PHTHALATE WERE CONVERTED TO MG/L DUE TO 8 DIGIT LIMIT IN PCS. NOTE THAT THE UG/L AND LBS/DAY LIMITS FOR TCDD EQUIVALENTS WERE CONVERTED TO PG/L AND UG/DAY.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: CARMEL AREA WWD & PEBBLE BEACH
ADDRESS: 26900 STATE ROUTE ONE
CARMEL, CA 93922

FACILITY: CARMEL AREA WWTP
LOCATION: 26900 STATE ROUTE ONE
CARMEL, CA 93922

ATTN: James Pinkevich

CA0047996
PERMIT NUMBER

001-S
DISCHARGE NUMBER

DMR Mailing ZIP CODE: 93922

MAJOR (SUBR 03)
DISCHARGE 001/SEMIANNUALLY
External Outfall

MONITORING PERIOD
MM/DD/YYYY TO MM/DD/YYYY
07/01/2013 TO 12/31/2013

No Discharge

PARAMETER	SAMPLE MEASUREMENT PERMIT REQUIREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	UNITS	VALUE	UNITS	VALUE	UNITS			
2,4-Dinitrotoluene	MEASUREMENT	NOI (B)	*****	*****	*****	*****				
	PERMIT REQUIREMENT	7.9 30DA AVG	lb/d	*****	*****	320 30DA AVG	ug/L	Twice Per Year	COMP24	
2,4-Dinitrophenol	MEASUREMENT	NOI (B)	*****	*****	*****	*****				
	PERMIT REQUIREMENT	12 30DA AVG	lb/d	*****	*****	490 30DA AVG	ug/L	Twice Per Year	COMP24	
2,4,6-Trichlorophenol	MEASUREMENT	NOI (B)	*****	*****	*****	*****				
	PERMIT REQUIREMENT	.89 30DA AVG	lb/d	*****	*****	35.38 30DA AVG	ug/L	Twice Per Year	COMP24	
3,3'-Dichlorobenzidine	MEASUREMENT	NOI (B)	*****	*****	*****	*****				
	PERMIT REQUIREMENT	.025 30DA AVG	lb/d	*****	*****	.99 30DA AVG	ug/L	Twice Per Year	COMP24	
Bis(2-ethylhexyl) phthalate	MEASUREMENT	NOI (B)	*****	*****	*****	*****				
	PERMIT REQUIREMENT	11 30DA AVG	lb/d	*****	*****	430 30DA AVG	ug/L	Twice Per Year	COMP24	
39100 1 0 Effluent Gross	MEASUREMENT	NOI (B)	*****	*****	*****	*****				
	PERMIT REQUIREMENT	1000 30DA AVG	lb/d	*****	*****	430000 30DA AVG	ug/L	Twice Per Year	COMP24	
Benzidine	MEASUREMENT	NOI (B)	*****	*****	*****	*****				
	PERMIT REQUIREMENT	.0021 30DA AVG	lb/d	*****	*****	.00842 30DA AVG	ug/L	Twice Per Year	COMP24	

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
BARBARA BUKEMBA
GENERAL MANAGER

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT
Barbara Bukemba

TELEPHONE DATE
(831) 624-1249 01/22/2014
AREA Code NUMBER MMDDYYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NOTE THAT THE UG/L LIMITS FOR DIMETHYL PHTHALATE WERE CONVERTED TO MG/L DUE TO 8 DIGIT LIMIT IN PCS. NOTE THAT THE UG/L AND LBS/DAY LIMITS FOR TCDD EQUIVALENTS WERE CONVERTED TO PG/L AND UG/DAY.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: CARMEL AREA WWD & PEBBLE BEACH
ADDRESS: 26900 STATE ROUTE ONE
CARMEL, CA 93922

CA0047996
PERMIT NUMBER

001-S
DISCHARGE NUMBER

DMR Mailing ZIP CODE: 93922
MAJOR (SUBR 03)
DISCHARGE 001/SEMIANNUALLY
External Outfall

FACILITY: CARMEL AREA WWTP
LOCATION: 26900 STATE ROUTE ONE
CARMEL, CA 93922

MONITORING PERIOD
MM/DD/YYYY TO MM/DD/YYYY
07/01/2013 TO 12/31/2013

FROM


ATTN: James Pinkevich

No Discharge

PARAMETER	QUANTITY OR LOADING		QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
	VALUE	UNITS	VALUE	UNITS	VALUE	UNITS			
Vinyl chloride	SAMPLE MEASUREMENT	NOI (B)	*****		*****				
	PERMIT REQUIREMENT	110 30DA AVG	lb/d	*****		4390 30DA AVG	ug/L	Twice Per Year	COMP24
Trichloroethylene	SAMPLE MEASUREMENT	NOI (B)	*****		*****				
	PERMIT REQUIREMENT	82 30DA AVG	lb/d	*****		3290 30DA AVG	ug/L	Twice Per Year	COMP24
Aldrin	SAMPLE MEASUREMENT	NOI (B)	*****		*****				
	PERMIT REQUIREMENT	.000067 30DA AVG	lb/d	*****		.00288 30DA AVG	ug/L	Twice Per Year	COMP24
Chlordane (tech mix. and metabolites)	SAMPLE MEASUREMENT	NOI (B)	*****		*****				
	PERMIT REQUIREMENT	.00007 30DA AVG	lb/d	*****		.00281 30DA AVG	ug/L	Twice Per Year	COMP24
Dieldrin	SAMPLE MEASUREMENT	NOI (B)	*****		*****				
	PERMIT REQUIREMENT	.00012 30DA AVG	lb/d	*****		.00488 30DA AVG	ug/L	Twice Per Year	COMP24
Endosulfan, total	SAMPLE MEASUREMENT	NOI (B)	*****		*****				
	PERMIT REQUIREMENT	.027 6 MO MED	lb/d	*****		1.1 6 MO MED	ug/L	Twice Per Year	COMP24
Endrin	SAMPLE MEASUREMENT	NOI (B)	*****		*****				
	PERMIT REQUIREMENT	.0061 6 MO MED	lb/d	*****		.24 6 MO MED	ug/L	Twice Per Year	COMP24
39175 1 0 Effluent Gross	SAMPLE MEASUREMENT	NOI (B)	*****		*****				
	PERMIT REQUIREMENT	.055 DAILY MX	lb/d	*****		3.29 INST MAX	ug/L	Twice Per Year	COMP24
39388 1 0 Effluent Gross	SAMPLE MEASUREMENT	NOI (B)	*****		*****				
	PERMIT REQUIREMENT	.012 DAILY MX	lb/d	*****		.73 INST MAX	ug/L	Twice Per Year	COMP24
39390 1 0 Effluent Gross	SAMPLE MEASUREMENT	NOI (B)	*****		*****				
	PERMIT REQUIREMENT	.0061 6 MO MED	lb/d	*****		.49 DAILY MX	ug/L	Twice Per Year	COMP24

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the reporting system, I am aware that there are significant differences between the data and the information submitted to the best of my knowledge and belief. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
BARBARA BUIKEMA
GENERAL MANAGER
TYPED OR PRINTED

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT


TELEPHONE
(831) 624-1249

DATE
01/20/2014

AREA Code NUMBER
MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NOTE THAT THE UG/L LIMITS FOR DIMETHYL PHTHALATE WERE CONVERTED TO MG/L DUE TO 8 DIGIT LIMIT IN PCS. NOTE THAT THE UG/L AND LBS/DAY LIMITS FOR TCDD EQUIVALENTS WERE CONVERTED TO PG/L AND UG/DAY.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: CARMEL AREA WWD & PEBBLE BEACH
ADDRESS: 26900 STATE ROUTE ONE
CARMEL, CA 93922

CA0047996
PERMIT NUMBER

001-S
DISCHARGE NUMBER

DMR Mailing ZIP CODE: 93922
MAJOR (SUBR 03)

FACILITY: CARMEL AREA WWTP

LOCATION: 26900 STATE ROUTE ONE
CARMEL, CA 93922


MONITORING PERIOD
MM/DD/YYYY TO MM/DD/YYYY
07/01/2013 TO 12/31/2013

DISCHARGE 001/SEMIANNUALLY
External Outfall

No Discharge

ATTN: James Pinkevich

PARAMETER	QUANTITY OR LOADING		QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Toxaphene									
39400 1 0 Effluent Gross	.00064 30DA AVG	lb/d	NOPI (B)	NOPI (B)	.02562 30DA AVG	ug/L	Twice Per Year	COMP24	
Heptachlor									
39410 1 0 Effluent Gross	.00015 30DA AVG	lb/d	NOPI (B)	NOPI (B)	.006 30DA AVG	ug/L	Twice Per Year	COMP24	
Heptachlor epoxide									
39420 1 0 Effluent Gross	.000061 30DA AVG	lb/d	NOPI (B)	NOPI (B)	.002 30DA AVG	ug/L	Twice Per Year	COMP24	
Polychlorinated biphenyls (PCBs)									
39516 1 0 Effluent Gross	.000058 30DA AVG	lb/d	NOPI (B)	NOPI (B)	.00232 30DA AVG	ug/L	Twice Per Year	COMP24	
Hexachlorobenzene									
39700 1 0 Effluent Gross	.00064 30DA AVG	lb/d	NOPI (B)	NOPI (B)	.02562 30DA AVG	ug/L	Twice Per Year	COMP24	
Mercury, total recoverable									
71901 1 0 Effluent Gross	.12 6 MO MED	lb/d	NOPI (B)	NOPI (B)	19.46 DAILY MX	ug/L	Twice Per Year	COMP24	
Phenols, chlorinated									
74015 1 0 Effluent Gross	3.1 6 MO MED	lb/d	NOPI (B)	NOPI (B)	490 DAILY MX	ug/L	Twice Per Year	COMP24	

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER <i>BARBARA BUKENA</i> General Manager	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT 	TELEPHONE (851) 624-1249	DATE 01/20/2014
TYPED OR PRINTED		AREA Code	NUMBER
			MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NOTE THAT THE UG/L LIMITS FOR DIMETHYL PHTHALATE WERE CONVERTED TO MG/L DUE TO 8 DIGIT LIMIT IN PCS. NOTE THAT THE UG/L AND LBS/DAY LIMITS FOR TCDD EQUIVALENTS WERE CONVERTED TO PG/L AND UG/DAY.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: CARMEL AREA WWD & PEBBLE BEACH
ADDRESS: 26900 STATE ROUTE ONE
CARMEL, CA 93922

CA0047996
PERMIT NUMBER

001-S
DISCHARGE NUMBER

DMR Mailing ZIP CODE: 93922
MAJOR (SUBR 03)

FACILITY: CARMEL AREA WWTP
LOCATION: 26900 STATE ROUTE ONE
CARMEL, CA 93922

MONITORING PERIOD
MM/DD/YYYY TO MM/DD/YYYY
07/01/2013 TO 12/31/2013

DISCHARGE 001/SEMIANNUALLY
External Outfall

No Discharge

ATTN: James Pinkevich

PARAMETER	QUANTITY OR LOADING		QUANTITY OR CONCENTRATION		NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
	VALUE	UNITS	VALUE	UNITS			
1,3-Dichloropropene							
77163 1 0 Effluent Gross	MEASUREMENT	NOPI (B)					
	PERMIT REQUIREMENT	27 30DA AVG	*****				
Hexachlorocyclohexane, total							
77835 1 0 Effluent Gross	MEASUREMENT	NOPI (B)					
	PERMIT REQUIREMENT	012 6 MO MED	NOPI (B)	398 DAILY MX		Twice Per Year	COMP24
Phenolic compounds, unchlorinated							
78218 1 0 Effluent Gross	MEASUREMENT	NOPI (B)					
	PERMIT REQUIREMENT	92 6 MO MED	NOPI (B)	14640 DAILY MX		Twice Per Year	COMP24
Halomethanes, sum							
78456 1 0 Effluent Gross	MEASUREMENT	NOPI (B)					
	PERMIT REQUIREMENT	400 30DA AVG	NOPI (B)	15860 30DA AVG		Twice Per Year	COMP24
Dichlorobenzene							
81524 1 0 Effluent Gross	MEASUREMENT	NOPI (B)					
	PERMIT REQUIREMENT	16000 30DA AVG	NOPI (B)	620000 30DA AVG		Twice Per Year	COMP24
TCDD equivalents							
82698 1 0 Effluent Gross	MEASUREMENT	NOPI (B)					
	PERMIT REQUIREMENT	5.443 30DA AVG	NOPI (B)	48 30DA AVG		Twice Per Year	COMP24
Static Renewal 96Hr Acute Pimphales Promelas							
TSN6C 1 0 Effluent Gross	MEASUREMENT	*****	*****	*****			
	PERMIT REQUIREMENT	*****	*****	3.9 DAILY MX		Twice Per Year	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER <i>BABARA BUIKEMA</i> General Manager	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT <i>James Pinkevich</i>	TELEPHONE (931) 624-1249	DATE 01/29/2014
TYPED OR PRINTED		AREA Code	NUMBER
COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)		MM/DD/YYYY	

NOTE THAT THE UG/L LIMITS FOR DIMETHYL PHTHALATE WERE CONVERTED TO MG/L DUE TO 8 DIGIT LIMIT IN PCS. NOTE THAT THE UG/L AND LBS/DAY LIMITS FOR TCDD EQUIVALENTS WERE CONVERTED TO PG/L AND UG/DAY.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: CARMEL AREA WWD & PEBBLE BEACH
ADDRESS: 26900 STATE ROUTE ONE
CARMEL, CA 93922

FACILITY: CARMEL AREA WWTP
LOCATION: 26900 STATE ROUTE ONE
CARMEL, CA 93922

ATTN: James Pinkevich

CA0047996
PERMIT NUMBER

001-S
DISCHARGE NUMBER

DMR Mailing ZIP CODE: 93922
MAJOR (SUBR 03)
DISCHARGE 001/SEMIANNUALLY
External Outfall

No Discharge

MONITORING PERIOD
MM/DD/YYYY TO MM/DD/YYYY
07/01/2013 TO 12/31/2013

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING				QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	UNITS	VALUE	UNITS	VALUE	UNITS	VALUE	UNITS			
Static 48Hr Chronic Haliotis Rufescens		*****	*****	*****	*****	*****	*****	*****	*****			
TTK3R 1.0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	122 DAILY MX	122 DAILY MX	122 DAILY MX	122 DAILY MX	toxic chronic	Twice Per Year	GRAB

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, I am satisfied that the information submitted is true, accurate, and complete. I am also satisfied that the information submitted is for the best of my knowledge and belief, true, accurate, and complete. I understand that anyone who furnishes false or misleading information on this report or who omits material or information requested on the report may be subject to criminal sanctions (including fines and imprisonment) and/or civil penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
Deborah Sullivan
General Manager
TYPED OR PRINTED

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT
Deborah Sullivan

TELEPHONE DATE
(831) 624-1249 01/29/2013
AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NOTE THAT THE UG/L LIMITS FOR DIMETHYL PHTHALATE WERE CONVERTED TO MG/L DUE TO 8 DIGIT LIMIT IN PCS. NOTE THAT THE UG/L AND LBS/DAY LIMITS FOR TCDD EQUIVALENTS WERE CONVERTED TO PG/L AND UG/DAY.