

Date: April 30, 2013

Division of Water Quality
C/O DMR Processing Center
P.O. Box 100
Sacramento, CA 95812-1000



Facility Name: Carmel Area Wastewater District

Address (mailing): P.O. Box 221428, Carmel, CA 93922

Address (shipping): Highway One & Carmel River, Carmel, CA 93923

Contact Person: James Pinkevich

Job Title: Plant Manager

Phone Number: 831-624-1249

WDR/NPDES Order Number: #R3-2008-0007 (NPDES PERMIT – CA0047996)

WDID Number: 3 270101001

Type of Report (circle one): Monthly Quarterly Semi-Annual Annual

Month(s) (circle applicable Months*):

Jan	Feb	March	Apr	May	Jun
Jul	Aug	Sept	Oct	Nov	Dec

*Annual Reports (circle the first month of the reporting period)

Year: 2013

Violation(s): No (there are no violations to report) Yes

If Yes is marked (complete a-g):

a) Parameter(s) in Violation: n/a

b) Section(s) of WDR/NPDES Violated: n/a

c) Reported Value(s): n/a

d) WDR/NPDES Limit Condition: n/a

e) Dates of Violation(s): n/a
(reference page of report/data sheet)

f) Explanation of Cause(s): n/a
(attach additional information as needed)

g) Corrective Action(s): n/a
(attach additional information as needed)

In accordance with the Standard Provisions and Reporting Requirements, I certify under penalty of law that this document and all attachments were prepared under my direction or supervision following a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my knowledge of the person(s) who manage the system or those directly responsible for data gathering, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment.

If you have any questions or require additional information, please contact me at the number provided above.

Sincerely,



James Pinkevich
Plant Manager

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: CARMEL AREA WWD & PEBBLE BEACH
ADDRESS: 26900 STATE ROUTE ONE
CARMEL, CA 93922

FACILITY: CARMEL AREA WWTP
LOCATION: 26900 STATE ROUTE ONE
CARMEL, CA 93922

ATTN: James Pinkevich

CA0047996
PERMIT NUMBER

001-S
DISCHARGE NUMBER

DMR Mailing ZIP CODE: 93922
MAJOR (SUBR 03)
DISCHARGE 001/SEMIANNUALLY
External Outfall

MONITORING PERIOD
MM/DD/YYYY TO MM/DD/YYYY
01/01/2013 TO 06/30/2013

No Discharge

PARAMETER	QUANTITY OR LOADING		QUALITY OR CONCENTRATION		NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
	VALUE	UNITS	VALUE	UNITS			
Radioactivity	*****	*****	*****	*****			
00189 1 0 Effluent Gross	*****	*****	*****	*****			
Cyanide, total (as CN)							
00720 1 0 Effluent Gross	3.1 6 MO MED	lb/d	232 490 DAILY MX	232 1220 INST MAX		Twice Per Year	COMP24
Arsenic, total recoverable							
00978 1 0 Effluent Gross	15 6 MO MED	lb/d	1.2 3540 DAILY MX	1.2 9400 INST MAX		Twice Per Year	COMP24
Selenium, total recoverable							
00981 1 0 Effluent Gross	46 6 MO MED	lb/d	2.2 7320 DAILY MX	2.2 18300 INST MAX		Twice Per Year	COMP24
Thallium, total recoverable							
00982 1 0 Effluent Gross	6.1 30DA AVG	lb/d	NOI (S) 240 30DA AVG	***** *****		Twice Per Year	COMP24
Beryllium, total recoverable (as Be)							
00998 1 0 Effluent Gross	30DA ¹ AVG	lb/d	NOI (S) 4.03 30DA AVG	***** *****		Twice Per Year	COMP24
Chromium, hexavalent (as Cr)							
01032 1 0 Effluent Gross	6.1 6 MO MED	lb/d	NOI (S) 980 DAILY MX	2440 INST MAX		Twice Per Year	COMP24

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and report the information and that the information submitted herein is true, accurate, and complete; I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
William B. Borsari
TYPED OR PRINTED

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE DATE
(831) 624-1249 4/30/13
AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NOTE THAT THE UG/L LIMITS FOR DIMETHYL PHTHALATE WERE CONVERTED TO MG/L DUE TO 8 DIGIT LIMIT IN POS. NOTE THAT THE UG/L AND LBS/DAY LIMITS FOR TCDD EQUIVALENTS WERE CONVERTED TO PG/L AND UG/DAY.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: CARMEL AREA WWD & PEBBLE BEACH
ADDRESS: 26900 STATE ROUTE ONE
CARMEL, CA 93922

FACILITY: CARMEL AREA WWTP
LOCATION: 26900 STATE ROUTE ONE
CARMEL, CA 93922

ATTN: James Pinkevich

CA0047996
PERMIT NUMBER

001-S
DISCHARGE NUMBER

DMR Mailing ZIP CODE: 93922

MAJOR (SUBR 03)
DISCHARGE 001/SEMIANNUALLY
External Outfall

MONITORING PERIOD
MM/DD/YYYY TO MM/DD/YYYY
01/01/2013 TO 06/30/2013

No Discharge

PARAMETER	SAMPLE MEASUREMENT REQUIREMENT	QUANTITY OR LOADING		QUALITY OR CONCENTRATION		NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	UNITS	VALUE	UNITS			
Chromium, trivalent (as Cr)	MEASUREMENT PERMIT REQUIREMENT	580000 30DA AVG	lb/d	NOI (S)	NOI (S)			
01033 1 0 Effluent Gross	PERMIT REQUIREMENT	580000 30DA AVG	lb/d	NOI (S)	23180000 30DA AVG		Twice Per Year	COMP24
Nickel, total recoverable	MEASUREMENT PERMIT REQUIREMENT	15 6 MO MED	lb/d	NOI (S)	9.2			
01074 1 0 Effluent Gross	PERMIT REQUIREMENT	15 6 MO MED	lb/d	NOI (S)	2440 DAILY MX		Twice Per Year	COMP24
Silver total recoverable	MEASUREMENT PERMIT REQUIREMENT	1.7 6 MO MED	lb/d	NOI (S)	NOI (S)			
01079 1 0 Effluent Gross	PERMIT REQUIREMENT	1.7 6 MO MED	lb/d	NOI (S)	70 6 MO MED		Twice Per Year	COMP24
Cadmium, total recoverable	MEASUREMENT PERMIT REQUIREMENT	3.1 6 MO MED	lb/d	NOI (S)	NOI (S)			
01113 1 0 Effluent Gross	PERMIT REQUIREMENT	3.1 6 MO MED	lb/d	NOI (S)	840 INST MAX		Twice Per Year	COMP24
Lead, total recoverable	MEASUREMENT PERMIT REQUIREMENT	24 6 MO MED	lb/d	NOI (S)	NOI (S)			
01114 1 0 Effluent Gross	PERMIT REQUIREMENT	24 6 MO MED	lb/d	NOI (S)	120 DAILY MX		Twice Per Year	COMP24
Antimony, total recoverable	MEASUREMENT PERMIT REQUIREMENT	3700 30DA AVG	lb/d	NOI (S)	NOI (S)			
01268 1 0 Effluent Gross	PERMIT REQUIREMENT	3700 30DA AVG	lb/d	NOI (S)	4.84		Twice Per Year	COMP24
2-Methyl-4,6-dinitrophenol	MEASUREMENT PERMIT REQUIREMENT	670 30DA AVG	lb/d	NOI (S)	NOI (S)			
03615 1 0 Effluent Gross	PERMIT REQUIREMENT	670 30DA AVG	lb/d	NOI (S)	26840 30DA AVG		Twice Per Year	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER <i>Buikema Baerwald</i> GENERAL MANAGER	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE (831) 624-1249	DATE 4/30/13
TYPED OR PRINTED		AREA Code	NUMBER
			MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
NOTE THAT THE UG/L LIMITS FOR DIMETHYL PHTHALATE WERE CONVERTED TO MG/L DUE TO 8 DIGIT LIMIT IN PCS. NOTE THAT THE UG/L AND LBS/DAY LIMITS FOR TCDD EQUIVALENTS WERE CONVERTED TO PG/L AND UG/DAY.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: CARMEL AREA WWD & PEBBLE BEACH
ADDRESS: 26900 STATE ROUTE ONE
CARMEL, CA 93922

FACILITY: CARMEL AREA WWTP
LOCATION: 26900 STATE ROUTE ONE
CARMEL, CA 93922

ATTN: James Pinkewich

CA0047996
PERMIT NUMBER

001-S
DISCHARGE NUMBER

DMR Mailing ZIP CODE: 93922
MAJOR (SUBR 03)

DISCHARGE 001/SEMIANNUALLY
External Outfall

No Discharge

MONITORING PERIOD
MM/DD/YYYY TO MM/DD/YYYY
01/01/2013 TO 06/30/2013

PARAMETER	SAMPLE MEASUREMENT PERMIT REQUIREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION			NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	UNITS	VALUE	UNITS	VALUE	UNITS			
Toluene	MEASUREMENT	*****		*****		*****				
34010 10 Effluent Gross	PERMIT REQUIREMENT	260000 30DA AVG	lb/d	*****		10370000 30DA AVG	ug/L		Twice Per Year	COMP24
Benzene	MEASUREMENT	*****		*****		NOI (b)				
34030 1 0 Effluent Gross	PERMIT REQUIREMENT	18 30DA AVG	lb/d	*****		720 30DA AVG	ug/L		Twice Per Year	COMP24
Acrolein	MEASUREMENT	*****		*****		NOI (b)				
34210 1 0 Effluent Gross	PERMIT REQUIREMENT	670 30DA AVG	lb/d	*****		26840 30DA AVG	ug/L		Twice Per Year	COMP24
Acrylonitrile	MEASUREMENT	*****		*****		NOI (b)				
34215 1 0 Effluent Gross	PERMIT REQUIREMENT	.31 30DA AVG	lb/d	*****		12.2 30DA AVG	ug/L		Twice Per Year	COMP24
Bis(2-chloroethyl) ether	MEASUREMENT	*****		*****		NOI (b)				
34273 1 0 Effluent Gross	PERMIT REQUIREMENT	.14 30DA AVG	lb/d	*****		5.49 30DA AVG	ug/L		Twice Per Year	COMP24
Bis(2-chloroethoxy)methane	MEASUREMENT	*****		*****		NOI (b)				
34278 1 0 Effluent Gross	PERMIT REQUIREMENT	13 30DA AVG	lb/d	*****		540 30DA AVG	ug/L		Twice Per Year	COMP24
Bis(2-chloroisopropyl) ether	MEASUREMENT	*****		*****		NOI (b)				
34283 1 0 Effluent Gross	PERMIT REQUIREMENT	3700 30DA AVG	lb/d	*****		15000 30DA AVG	ug/L		Twice Per Year	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER <i>DICKENA BARAKAT</i> GENERAL MANAGER	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE	DATE
		(831) 627-2249	4/30/13
TYPED OR PRINTED		AREA Code	NUMBER
			MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
NOTE THAT THE UG/L LIMITS FOR DIMETHYL PHTHALATE WERE CONVERTED TO MG/L DUE TO 8 DIGIT LIMIT IN PCS. NOTE THAT THE UG/L AND LBS/DAY LIMITS FOR TCDD EQUIVALENTS WERE CONVERTED TO PG/L AND UG/DAY.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: CARMEL AREA WWD & PEBBLE BEACH
ADDRESS: 26900 STATE ROUTE ONE
CARMEL, CA 93922

FACILITY: CARMEL AREA WWTP
LOCATION: 26900 STATE ROUTE ONE
CARMEL, CA 93922

ATTN: James Pinkevich

CA0047996
PERMIT NUMBER

001-S
DISCHARGE NUMBER

DMR Mailing ZIP CODE: 93922
MAJOR (SUBR 03)
DISCHARGE 001/SEMIANNUALLY
External Outfall

No Discharge

MONITORING PERIOD
MM/DD/YYYY TO MM/DD/YYYY
01/01/2013 TO 06/30/2013

PARAMETER	SAMPLE MEASUREMENT REQUIREMENT	QUANTITY OR LOADING		QUALITY OR CONCENTRATION		NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	UNITS	VALUE	UNITS			
Hexachlorobutadiene	34391 1 0 Effluent Gross	NOI (LB)	lb/d	*****	*****			
		43 30DA AVG		*****	*****		Twice Per Year	COMP24
Hexachloroethane	34396 1 0 Effluent Gross	NOI (LB)	lb/d	*****	*****			
		7.6 30DA AVG		*****	*****		Twice Per Year	COMP24
Isophorone	34408 1 0 Effluent Gross	NOI (LB)	lb/d	*****	*****			
		2228 30DA AVG		*****	*****		Twice Per Year	COMP24
Methylene chloride	34423 1 0 Effluent Gross	NOI (LB)	lb/d	*****	*****			
		1400 30DA AVG		*****	*****		Twice Per Year	COMP24
N-Nitrosodi-N-propylamine	34428 1 0 Effluent Gross	NOI (LB)	lb/d	*****	*****			
		1.2 30DA AVG		*****	*****		Twice Per Year	COMP24
N-Nitrosodiphenylamine	34433 1 0 Effluent Gross	NOI (LB)	lb/d	*****	*****			
		7.6 30DA AVG		*****	*****		Twice Per Year	COMP24
N-Nitrosodimethylamine (NDMA)	34438 1 0 Effluent Gross	NOI (LB)	lb/d	*****	*****			
		22 30DA AVG		*****	*****		Twice Per Year	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER <i>BRIENNA BARBARA GENERAL MANAGER</i>	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE (831) 624-1244	DATE 4/30/13
TYPED OR PRINTED	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NOTE THAT THE UG/L LIMITS FOR DIMETHYL PHTHALATE WERE CONVERTED TO MG/L DUE TO 8 DIGIT LIMIT IN PCS. NOTE THAT THE UG/L AND LBS/DAY LIMITS FOR TCDD EQUIVALENTS WERE CONVERTED TO PG/L AND UG/DAY.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: CARMEL AREA WWD & PEBBLE BEACH
ADDRESS: 26900 STATE ROUTE ONE
CARMEL, CA 93922

CA0047996
PERMIT NUMBER

001-S
DISCHARGE NUMBER

DMR Mailing ZIP CODE: 93922
MAJOR (SUBR 03)

FACILITY: CARMEL AREA WWTP
LOCATION: 26900 STATE ROUTE ONE
CARMEL, CA 93922

MONITORING PERIOD
MM/DD/YYYY TO MM/DD/YYYY
01/01/2013 TO 06/30/2013

DISCHARGE 001/SEMIANNUALLY
External Outfall

ATTN: James Pinkevich

No Discharge

PARAMETER	QUANTITY OR LOADING		QUALITY OR CONCENTRATION		NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
	VALUE	UNITS	VALUE	UNITS			
2,4-Dinitrotoluene	NOI (LB)		*****				
34611 1 0 Effluent Gross	7.9 30DA AVG	lb/d	***** NOI (LB)	320 30DA AVG		Twice Per Year	COMP24
2,4-Dinitrophenol	NOI (LB)		*****				
34616 1 0 Effluent Gross	12 30DA AVG	lb/d	***** NOI (LB)	490 30DA AVG		Twice Per Year	COMP24
2,4,6-Trichlorophenol	NOI (LB)		*****				
34621 1 0 Effluent Gross	.89 30DA AVG	lb/d	***** NOI (LB)	35.38 30DA AVG		Twice Per Year	COMP24
3,3'-Dichlorobenzidine	NOI (LB)		*****				
34631 1 0 Effluent Gross	.025 30DA AVG	lb/d	***** NOI (LB)	99 30DA AVG		Twice Per Year	COMP24
Bis(2-ethylhexyl) phthalate	NOI (LB)		*****				
39100 1 0 Effluent Gross	11 30DA AVG	lb/d	***** NOI (LB)	430 30DA AVG		Twice Per Year	COMP24
Di-n-butyl phthalate	NOI (LB)		*****				
39110 1 0 Effluent Gross	11000 30DA AVG	lb/d	***** NOI (LB)	430000 30DA AVG		Twice Per Year	COMP24
Benzidine	NOI (LB)		*****				
39120 1 0 Effluent Gross	.0021 30DA AVG	lb/d	***** NOI (LB)	.00842 30DA AVG		Twice Per Year	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
DUKEMA BARBARA
GENERAL MANAGER

TYPED OR PRINTED

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE: (831) 624-1249
DATE: 4/30/13
NUMBER: MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NOTE THAT THE UG/L LIMITS FOR DIMETHYL PHTHALATE WERE CONVERTED TO MG/L DUE TO 8 DIGIT LIMIT IN PCS. NOTE THAT THE UG/L AND LBS/DAY LIMITS FOR TCDD EQUIVALENTS WERE CONVERTED TO PG/L AND UG/DAY.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: CARMEL AREA WWD & PEBBLE BEACH
ADDRESS: 26900 STATE ROUTE ONE
CARMEL, CA 93922

FACILITY: CARMEL AREA WWTP
LOCATION: 26900 STATE ROUTE ONE
CARMEL, CA 93922

ATTN: James Pinkevich

CA0047996
PERMIT NUMBER

001-S
DISCHARGE NUMBER

DMR Mailing ZIP CODE: 93922

MAJOR (SUBR 03)
DISCHARGE 001/SEMIANNUALLY
External Outfall

No Discharge

MONITORING PERIOD
MM/DD/YYYY TO MM/DD/YYYY
01/01/2013 TO 06/30/2013

PARAMETER	QUANTITY OR LOADING		QUALITY OR CONCENTRATION		NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
	VALUE	UNITS	VALUE	UNITS			
Toxaphene							
39400 1 0 Effluent Gross	NOI (B)	lb/d	NOI (B)	ug/L		Twice Per Year	COMP24
Heptachlor							
39410 1 0 Effluent Gross	NOI (B)	lb/d	NOI (B)	ug/L		Twice Per Year	COMP24
Heptachlor epoxide							
39420 1 0 Effluent Gross	NOI (B)	lb/d	NOI (B)	ug/L		Twice Per Year	COMP24
Polychlorinated biphenyls (PCBs)							
39516 1 0 Effluent Gross	NOI (B)	lb/d	NOI (B)	ug/L		Twice Per Year	COMP24
Hexachlorobenzene							
39700 1 0 Effluent Gross	NOI (B)	lb/d	NOI (B)	ug/L		Twice Per Year	COMP24
Mercury, total recoverable							
71901 1 0 Effluent Gross	NOI (B)	lb/d	NOI (B)	ug/L		Twice Per Year	COMP24
Phenols, chlorinated							
74015 1 0 Effluent Gross	NOI (B)	lb/d	NOI (B)	ug/L		Twice Per Year	COMP24

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER <i>BILKINA, BARBARA</i> GENERAL MANAGER	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		TELEPHONE (831) 624-1249	DATE 4/30/13
	TYPED OR PRINTED		AREA Code NUMBER	MM/DD/YYYY MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
NOTE THAT THE UG/L LIMITS FOR DIMETHYL PHTHALATE WERE CONVERTED TO MGL/DUE TO 8 DIGIT LIMIT IN PCS. NOTE THAT THE UG/L AND LBS/DAY LIMITS FOR TCDD EQUIVALENTS WERE CONVERTED TO PG/L AND UG/DAY.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: CARMEL AREA WWD & PEBBLE BEACH
ADDRESS: 26900 STATE ROUTE ONE
CARMEL, CA 93922

FACILITY: CARMEL AREA WWTP
LOCATION: 26900 STATE ROUTE ONE
CARMEL, CA 93922

ATTN: James Pinkevich

CA0047996
PERMIT NUMBER

001-S
DISCHARGE NUMBER

DMR Mailing ZIP CODE: 93922
MAJOR (SUBR 03)

DISCHARGE 001/SEMIANNUALLY
External Outfall

No Discharge

MONITORING PERIOD
MM/DD/YYYY TO MM/DD/YYYY
01/01/2013 TO 06/30/2013

PARAMETER	QUANTITY OR LOADING		QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Static 48Hr Chronic Halotris Rufescens	*****	*****	*****	*****	*****	*****			
TTK3R 1 0 Effluent Gross	*****	*****	*****	*****	*****	*****	122 DAILY MIX	Twice Per Year	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
BARBARA B. ROBERTS
GENERAL MANAGER

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and analyze the information submitted and that the information submitted herein is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE NUMBER
(831) 624-1249

DATE
4/30/13

AREA Code NUMBER
MM/DD/YYYY
MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NOTE THAT THE UG/L LIMITS FOR DIMETHYL PHTHALATE WERE CONVERTED TO MG/L DUE TO 8 DIGIT LIMIT IN PCS. NOTE THAT THE UG/L AND LBS/DAY LIMITS FOR TCDD EQUIVALENTS WERE CONVERTED TO PG/L AND UG/DAY.